

1 Q. (Reference 2017 GRA Volume I, page 4.8 – 4.9) Is the additional 230 kV line from  
2 Soldiers Pond to Hardwoods being connected to the new Soldiers Pond facilities?  
3 What is the purpose of that line?

4

5

6 A. Yes, the replacement of the existing TL 201 230 kV line from Hardwoods to the  
7 vicinity of Soldiers Pond, now TL 266, will be connected to the new Soldiers Pond  
8 facility.

9

10 TL 266 is being rebuilt with an increased thermal rating as a result of a violation of  
11 transmission planning criteria when TL 217 is out of service.