

1 Q. **NLH Evidence, Section 5.9.1, p.5.36**

2 Citation:

3 The capital cost of new transmission line facilities servicing Labrador West from
4 Churchill Falls is projected to be in the range of \$5 to \$6 per kW.

5

6 a) Is this estimate based on the Labrador West Transmission Line? Please
7 provide detailed calculations in support of this figure.

8 a) Please describe other measures under review by Hydro to allow it to meet
9 additional requirements for capacity and energy in Labrador West at lower
10 cost (e.g. local generation, demand-side measures, storage, etc.).

11

12

13 A. a) Yes, this cost per kW-month is based on a cost estimate for the Labrador
14 West transmission line. The detailed calculations are provided in Hydro's
15 response to IOC-NLH-024.

16

17 b) Please refer to Hydro's response to IOC-NLH-021.