

1 Q. Further to the response to PUB-NLH-046, please identify the typical source(s) of the  
2 70 MW of additional reserve that “is not necessarily on-line but is available for a  
3 quick start in the event of a contingency event”.

4

5

6 A. The generation sources typically included in the 70 MW of additional reserve  
7 referenced in Hydro’s response to PUB-NLH-046 are hydro or standby units which  
8 are not on-line but are available to meet customer load. The sources also include  
9 Hydro’s capacity assistance arrangements and the delivery point voltage reduction  
10 strategy during the peak winter season.