

1 **Re: D-38, Purchase and Install a Voltage Regulator Bank, English Harbour**
2 **West, \$123,300**

3 Q. Please provide a table showing the load on the English Harbour West
4 Distribution System for each year from 2005 to 2008.

5

6

7 A. Table 1 below shows peak demand in kVA for the English Harbour West
8 Distribution System from 2005 to 2008.

9 **Table 1: English Harbour West Peak Demand 2005 to 2008**

Year	Demand (kVA)
2005	3,514
2006	3,024
2007	3,658
2008	3,542