

1 Q. **C-172, Replace Radomes, \$211,700**

2 If primary protection signals are transmitted, when did NLH start using the
3 microwave system for this purpose?

4

5

6 A. Hydro started using the microwave system for the transmission of primary
7 protection signals in 1998.