

1 **Q. Re 2011 AMR Project, Tab 4.3**

2

3 **Can the conventional meters which are being replaced by the AMR meters be re-**

4 **used or re-conditioned?**

5

6 A. Based on Measurement Canada specifications, it is not economical to re-use

7 electromechanical meters. For the 2011 AMR project approximately 40% of the meters to

8 be replaced are electromechanical and will not be re-used.

9

10 The remaining digital meters will be assessed at time of removal to determine the

11 feasibility of re-use based up on physical condition and remaining life as per

12 Measurement Canada specifications.