

1 Q. Please provide any historical and forecast Holyrood capacity factors presented to
2 the Board by Hydro in connection with the 1992 Generic Cost of Service Hearing.
3 (Volume II, Addendum to Exhibit 9, Section 2.3, page 2)

4

5

6 A. Historical and forecast capacity factors presented to the Board by Hydro in
7 connection with the 1992 Generic Cost of Service Hearing are shown in the table
8 below.

9

Annual Capacity Factors (%)

<u>1982</u>	<u>1983</u>	<u>1984</u>	<u>1985</u>	<u>1986</u>	<u>1987</u>	<u>1988</u>	<u>1989</u>	<u>1990</u>	<u>1991</u>	<u>1992 COS</u>
29.8	15.3	20.3	46.1	33.6	58.7	35.7	48.6	44.2	34.5	48.5

Source: Cost of Service Methodology Proceeding: NP-5 (1982 - 1990); NP-5 and GCB-6 (1991); and R.A. Bellin Evidence p.11, line 7 (1992 COS) which shows 51.5% Demand and thus 48.5% Energy which was based on capacity factor.