

1 Q. What is the elevation of the proposed new light fixtures and would bulb
2 replacement still require the use of a bucket truck? If not, how would bulbs be
3 replaced?

4

5

6 A. It is anticipated that the new light fixtures would be mounted at an elevation of
7 approximately 20' above the deck elevation. The new mounting height is nearly
8 half of the current fixture height of 35'.

9

10 Bulb replacements will continue to require the use of a bucket truck, however, the
11 size of the trucks would be greatly reduced. The equipment would be more of the
12 type utilized by local cable utilities or a small hydraulic lift which is readily available.
13 These smaller vehicles are much more mobile and do not require the use of
14 outriggers, thus, reducing the risk associated with changing out the bulbs.