

1 Q. **General**

2 Please identify any current capital projects for 2016 which are a result of or related  
3 to the Liberty Consulting Group recommendations contained in the report "*Island*  
4 *Interconnected System to Interconnection with Muskrat Falls addressing*  
5 *Newfoundland and Labrador Hydro*".

6

7

8 A. There are two projects for 2016 related to references in the Liberty Consulting  
9 Group recommendations in the report "*Island Interconnected System to*  
10 *Interconnection with Muskrat Falls addressing Newfoundland and Labrador Hydro*".

11 These are:

- 12 • Upgrade Circuit Breakers. This project involves an accelerated approach to  
13 replacing air blast circuit breakers.
- 14 • Perform Wood Pole Line Management Program. This project is a  
15 continuation of the program as a best practice.

16

17 Also, for 2016 there are 4 projects related to the recommendations in the interim  
18 report of April 24, 2014 entitled "*Supply issues and Power Outages Review – Island*  
19 *Interconnected System*". These are:

- 20 • Install Breaker Failure Protection.
- 21 • Upgrade Data Alarm Systems.
- 22 • Upgrade Digital fault Recorders.
- 23 • Replace Protective Relays.