

1 **Re: Page B-217, Safety Hazards Removal, \$252,300**

2 Q. Please provide a thorough description, including a copy of the report on the
3 hazards identified, of the Safe Work Observation Program.

4

5

6 A. The purpose of this proposal is to approve a block of funding to address
7 some items on a long list of deficiencies, each one contributing to a
8 hazardous condition. The following is a list of potential projects that would be
9 addressed under this capital project.

10

11

- Address grounding deficiencies at various sites.

12

- Install observation windows in man doors to gas turbine engine compartments at Hardwoods and Stephenville.

13

14

- Install enlarged man doors to improve access to gas turbine exhaust stacks at Hardwoods.

15

16

- Upgrade personal protection equipment (PPE) to improve arc flash protection.

17

18

- Install an access stairwell to fire pump pit at Granite Canal plant.

19

20

- Install an access stairway to draft tube gallery at Upper Salmon.

21

22

- Install platform and railing around Unit 3 condenser at Holyrood to improve emergency response egress.

23

24

- Modify access platform serving Unit 3 wind box dampers at Holyrood to improve access.

25

26

- Modify turbine condenser vacuum pump exhaust at Holyrood such that it exhausts to the outside.

27

- 1 • Erect enclosures to reduce the amount of heavy metal dust
- 2 migrating into the plant when boiler work is taking place at
- 3 Holyrood.
- 4 • Replace ladders with stair at various locations.
- 5 • Ventilation upgrades at various locations.
- 6 • Lighting upgrades at various locations.

7

8 This list is indicative of the broad array of miscellaneous safety hazards
9 which would be eliminated under this project.