


**Newfoundland Labrador Hydro (NLH)
Supply and Demand Status Report Filed April 07, 2014**

**Section 1
NLH System Island Interconnected Supply and Demand
Actual 24 Hour System Performance For April 06, 2014**



Supply Notes for April 06, 2014

- As of 0422 hours, Feb. 17, 2014, Bay d'Espoir Unit 6 (77 MW) unavailable for service.
- As of 1049 hours, April 04, 2014, Holyrood Unit 1 (170 MW) unavailable due to a planned maintenance outage.

**Section 2
NLH System Island Interconnected Supply and Demand**

April 7, 2014	NLH System Outlook ³	Five-Day Forecast		Temperature		NLH System Demand	
				Morning	Evening	Morning	Evening
Available NLH System Supply: ⁴	1,335 MW	Monday, April 07, 2014		-1	1	1,150	1,050
Current St. John's Temperature:	-1 °C	Tuesday, April 08, 2014		-4	1	1,150	1,025
Current St. John's Windchill:	-8 °C	Wednesday, April 09, 2014		2	7	1,075	950
NLH System Peak Demand Forecast:	1,150 MW	Thursday, April 10, 2014		2	2	1,100	1,075
		Friday, April 11, 2014		-4	2	1,175	925

Supply Notes for April 07, 2014³

- As of 0717 hours, Holyrood Unit 2 derated to 130 MW (from 170 MW) and Holyrood Unit 3 derated to 115 MW (from 150 MW).

Notes:

1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as underfrequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Underfrequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
3. As of 0800 Hours.
4. Gross output including station service at Holyrood (24.5 MW) and improved hydraulic output due to water levels (35 MW). Includes Nalcor Exploits, Star Lake, Rattle Brook, CBPP Co-Gen. Excludes wind generation and DLP Secondary.

**Section 3
Peak Demand Information
Previous Day Actual Peak and Current Day Forecast Peak**

April 6, 2014	Actual NLH System Island Interconnected Peak Demand ¹	11:20	1,155 MW
April 7, 2014	Forecast NLH System Island Interconnected Peak Demand		1,150 MW
April 6, 2014	Actual Total Island Peak Demand ²	12:00	1,318 MW
April 7, 2014	Forecast Total Island Peak Demand		1,300 MW

Notes:

1. NLH System Island Interconnected is supplied by generation owned by NLH as well as NLH Power Purchases as detailed in Section 1 above.
2. Total Island System Demand is supplied by NLH generation and NLH Power Purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper to meet their respective supply needs.