


Newfoundland Labrador Hydro (NLH)  
Supply and Demand Status Report Filed Tuesday, March 22, 2016

Section 1  
Island Interconnected System Supply and Demand  
Actual 24 Hour System Performance For Monday, March 21, 2016



Supply Notes For March 21, 2016

- 1,2
- A As of 1956 hours, January 14, 2016, Nalcor Exploits Grand Falls Unit 7 unavailable. No net impact to the Island Interconnected System.
- B As of 0710 hours, February 08, 2016, Holyrood Unit 2 derated to 120 MW (170 MW).
- C As of 2010 hours, February 26, 2016, Holyrood Unit 1 derated to 120 MW (170 MW).
- D As of 0732 hours, February 29, 2016, Hardwoods Gas Turbine derated to 38 MW (50 MW). End A 19 MW, End B 25 MW.
- E As of 1100 hours, March 16, 2016, St. Anthony Diesel Unit 546 unavailable (2 MW).

Section 2  
Island Interconnected Supply and Demand

Tue, Mar 22, 2016      Island System Outlook <sup>3</sup>			Seven-Day Forecast		Temperature (°C)		Island System Daily Peak Demand (MW)	
					Morning	Evening	Forecast	Adjusted <sup>6</sup>
Available Island System Supply: <sup>5</sup>	1,935	MW	Tuesday, March 22, 2016		3	-3	1,435	1,338
NLH Generation: <sup>4</sup>	1,580	MW	Wednesday, March 23, 2016		-5	-3	1,460	1,363
NLH Power Purchases: <sup>7</sup>	145	MW	Thursday, March 24, 2016		-7	-5	1,545	1,447
Other Island Generation:	210	MW	Friday, March 25, 2016		-6	-2	1,330	1,234
Current St. John's Temperature:	5	°C	Saturday, March 26, 2016		7	-2	1,280	1,185
Current St. John's Windchill:	N/A	°C	Sunday, March 27, 2016		-3	1	1,215	1,121
7-Day Island Peak Demand Forecast:	1,545	MW	Monday, March 28, 2016		2	5	1,215	1,121

Supply Notes For March 22, 2016

- 3
- Notes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Under frequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
3. As of 0800 Hours.
4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
5. Gross output from all Island sources (including Note 4).
6. Adjusted for CBP&P interruptible load (when applicable) and the impact of voltage reduction.
7. NLH Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Vale capacity assistance, and Wind Generation.

Section 3  
Island Peak Demand Information  
Previous Day Actual Peak and Current Day Forecast Peak

Mon, Mar 21, 2016	Actual Island Peak Demand <sup>8</sup>	07:45	1,467 MW
Tue, Mar 22, 2016	Forecast Island Peak Demand		1,435 MW

- Notes: 8. Island Demand is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).