

## Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Monday, March 28, 2016

A As of 1956 hours, January 14, 2016, Nalcor Exploits Grand Falls Unit 7 unavailable. No net impact to the Island Interconnected System.

**B** As of 0710 hours, February 08, 2016, Holyrood Unit 2 derated to 120 MW (170 MW).

- As of 2010 hours, February 26, 2016, Holyrood Unit 1 derated to 120 MW (170 MW).
- **D** As of 0732 hours, February 29, 2016, Hardwoods Gas Turbine derated to 38 MW (50 MW). End A 19 MW, End B 25 MW.

As of 1100 hours, March 16, 2016, St. Anthony Diesel Unit 546 unavailable (2 MW).

As of 1922 hours, March 24, 2016, Holyrood Combustion Turbine unavailable (123.5 MW).

At 1748 hours, March 25, 2016, Hawke's Bay Diesel Unit 2 available (2.5 MW).

	ls	land Int	Section 2 erconnected Supply and Demand					
Sat, Mar 26, 2016 Island System Outlook <sup>3</sup>			Seven-Day Forecast	-	Temperature (°C)		Island System Daily Peak Demand (MW)	
				Morning	Evening	Forecast	Adjusted <sup>6</sup>	
Available Island System Supply: <sup>5</sup>	1,655	MW	Saturday, March 26, 2016	2	-5	1,330	1,234	
NLH Generation: <sup>4</sup>	1,380	MW	Sunday, March 27, 2016	-5	-3	1,275	1,180	
NLH Power Purchases: <sup>7</sup>	130	MW	Monday, March 28, 2016	-3	-1	1,320	1,225	
Other Island Generation:	145	MW	Tuesday, March 29, 2016	3	2	1,275	1,180	
Current St. John's Temperature:	0	°C	Wednesday, March 30, 2016	-1	-2	1,355	1,259	
Current St. John's Windchill:	N/A	°C	Thursday, March 31, 2016	-2	2	1,335	1,239	
7-Day Island Peak Demand Forecast:	1,355	MW	Friday, April 01, 2016	8	11	1,035	1,035	
Supply Notes For March 26, 2016	3		•			-		
H At 0154 hours, March 26, 2016, Bay	d'Espoir Unit 1	unavaila	ble (76.5 MW).					

- Notes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
  - 2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Under frequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
  - 3. As of 0800 Hours.

С

Ε

G

- 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
- 5. Gross output from all Island sources (including Note 4).
- 6. Adjusted for CBP&P interruptible load (when applicable) and the impact of voltage reduction.
- 7. NLH Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Vale capacity assistance, and Wind Generation.

Section 3 Island Peak Demand Information						
Previous Day Actual Peak and Current Day Forecast Peak						
Fri, Mar 25, 2016	Actual Island Peak Demand <sup>8</sup>	08:45	1,375 MW			
Sat, Mar 26, 2016	Forecast Island Peak Demand		1,330 MW			