



Supply Notes For October 25, 2016

- As of 1956 hours, January 14, 2016, Nalcor Exploits Grand Falls Unit 7 unavailable. No net impact to the Island Interconnected System.
- As of 1526 hours, March 26, 2016, Stephenville Gas Turbine End A unavailable (25 MW).
- As of 1316 hours, July 15, 2016, Nalcor Exploits Grand Falls Unit 4 unavailable. Net impact to the Island Interconnected System is 7 MW.
- B C D E F G H As of 1341 hours, August 27, 2016, Holyrood Unit 1 unavailable. Previously derated to 120 MW (170 MW).
- As of 1719 hours, September 09, 2016, Nalcor Exploits Bishop's Falls plant units 7 and 9 unavailable. No net impact to the Island Interconnected System.
- As of 0717 hours, September 14, 2016, Bay d'Espoir Unit 1 unavailable (76.5 MW).
- As of 0717 hours, September 14, 2016, Bay d'Espoir Unit 2 unavailable (76.5 MW).
- As of 1956 hours, September 30, 2016, Paradise River Unit unavailable (8 MW).
- As of 2132 hours, October 10, 2016, Nalcor Exploits Bishop's Falls plant units 1,2,3,4,5,6 and 8 unavailable. Net impact to the Island Interconnected System is 15 MW.
- As of 1706 hours, October 22, 2016, Hardwoods Gas Turbine derated to 38 MW (50 MW).
- At 0815 hours, October 25, 2016, Cat Arm Unit 1 available (67 MW)

Isla Wed, Oct 26, 2016 Island System Outlook ³			nd Interconnected Supply and Dema Seven-Day Forecast	Tempo	erature C)	Island System Daily Peak Demand (MW)	
				Morning	Evening	Forecast	
Available Island System Supply: ⁵	1,580	MW	Wednesday, October 26, 2016	5	6	1,075	
NLH Generation: ⁴	1,325	MW	Thursday, October 27, 2016	5	3	1,130	
NLH Power Purchases: ⁶	90	MW	Friday, October 28, 2016	2	1	1,125	
Other Island Generation:	165	MW	Saturday, October 29, 2016	4	7	1,065	
Current St. John's Temperature:	3	°C	Sunday, October 30, 2016	10	9	940	
Current St. John's Windchill:	N/A	°C	Monday, October 31, 2016	7	5	1,045	
7-Day Island Peak Demand Forecast:	1,130	MW	Tuesday, November 01, 2016	5	2	1,060	
customer supply. The power low and sufficient supply rese 2. Due to the Island Interconnec customer's load must be inte referred to as under frequence	system operators s erves are available. Eted System being i rrupted for short p cy load shedding, is	chedule of However, solated fro eriods to k necessary	ce are included. These are not unusual for pow utages to system equipment whenever possib from time to time equipment outages are ner om the larger North American grid, when ther pring generation output equal to customer der y to ensure the integrity and reliability of syster	e to coincide with essary and reserve e is a sudden loss o nand. This automa m equipment. Un	periods when es may be impo of large genera tic action of po der frequency	customer demands are acted. ting units some ower system protection,	
 Jotes: Generation outages for runni customer supply. The power low and sufficient supply rese 2. Due to the Island Interconnec customer's load must be inte referred to as under frequence 8 times per year on the Island 3. As of 0800 Hours. Gross output including station 5. Gross output from all Island s 	ng and corrective r system operators s erves are available. Ered System being i rrupted for short p by load shedding, is I Interconnected Sy n service at Holyroo ources (including N	chedule of However, isolated fro eriods to k necessary ystem and od (24.5 M lote 4).	utages to system equipment whenever possib from time to time equipment outages are new om the larger North American grid, when ther pring generation output equal to customer der	e to coincide with essary and reserve e is a sudden loss of nand. This automa m equipment. Un generally less than o water levels (35 l	periods when es may be impo of large genera tic action of po der frequency of 30 minutes. MW).	customer demands are acted. ting units some ower system protection, events typically occur 5 to	
 Generation outages for runni customer supply. The power low and sufficient supply rese 2. Due to the Island Interconnec customer's load must be inte referred to as under frequenc 8 times per year on the Island 3. As of 0800 Hours. Gross output including station 5. Gross output from all Island s 	ng and corrective r system operators s erves are available. ted System being i rrupted for short p ty load shedding, is I Interconnected Sy n service at Holyroo ources (including N :: CBPP Co-Gen, Na	chedule of However, solated fro eriods to k necessary ystem and od (24.5 M lote 4). Icor Exploi	utages to system equipment whenever possib from time to time equipment outages are ner on the larger North American grid, when ther oring generation output equal to customer der y to ensure the integrity and reliability of syste the resultant customer load interruptions are IW) and improved NLH hydraulic output due to its, Rattle Brook, Star Lake, Vale capacity assis Section 3 Island Peak Demand Information	e to coincide with ressary and reserve e is a sudden loss of nand. This automa m equipment. Un generally less than o water levels (35 l rance (when applic	periods when es may be impo of large genera tic action of po der frequency of 30 minutes. MW).	customer demands are acted. ting units some ower system protection, events typically occur 5 to	
 Generation outages for runni customer supply. The power low and sufficient supply rese Due to the Island Interconnec customer's load must be inte referred to as under frequenc 8 times per year on the Island As of 0800 Hours. Gross output including station Gross output from all Island s NLH Power Purchases include 	ng and corrective r system operators s erves are available. ted System being i rrupted for short p y load shedding, is I Interconnected Sy n service at Holyroo ources (including N :: CBPP Co-Gen, Na	chedule of However, solated fro eriods to k necessary ystem and od (24.5 M loor Exploi	utages to system equipment whenever possib from time to time equipment outages are ner om the larger North American grid, when ther oring generation output equal to customer der y to ensure the integrity and reliability of syste the resultant customer load interruptions are IW) and improved NLH hydraulic output due to its, Rattle Brook, Star Lake, Vale capacity assis	e to coincide with ressary and reserve e is a sudden loss of nand. This automa m equipment. Un generally less than o water levels (35 l rance (when applic	periods when es may be impo of large genera tic action of po der frequency n 30 minutes. WW). nable), and Wir	customer demands are acted. ting units some ower system protection, events typically occur 5 to	