

Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Friday, January 13, 2017

As of 1719 hours, September 09, 2016, Nalcor Exploits Bishop's Falls plant unit 9 unavailable. No net impact to the Island Interconnected System.

С As of 2132 hours, October 10, 2016, Nalcor Exploits Bishop's Falls plant unit 8 unavailable. No net impact to the Island Interconnected System.

D As of 1920 hours, December 29, 2016, Holyrood Unit 1 derated to 160 MW (170 MW).

At 0756 hours, January 12, 2017, Cat Arm Unit 1 unavailable (67 MW).

At 1321 hours, January 12, 2017, Stephenville Gas Turbine End A available. Derated to 19 MW (25 MW).

At 1725 hours, January 12, 2017, Cat Arm Unit 1 available (67 MW). G

Fri, Jan 13, 2017 Island	l System Outl	ook ³	Seven-Day Forecast		erature C)	Island System Daily Peak Demand (MW	
				Morning	Evening	Forecast	Adjusted ⁷
Available Island System Supply: ⁵	2,025	MW	Friday, January 13, 2017	6	2	1,300	1,200
NLH Generation: ⁴	1,670	MW	Saturday, January 14, 2017	-10	-12	1,640	1,536
NLH Power Purchases: ⁶	165	MW	Sunday, January 15, 2017	-10	-6	1,580	1,477
Other Island Generation:	190	MW	Monday, January 16, 2017	-9	-11	1,660	1,556
Current St. John's Temperature:	7	°C	Tuesday, January 17, 2017	-6	-11	1,670	1,566
Current St. John's Windchill:	N/A	°C	Wednesday, January 18, 2017	-7	-5	1,560	1,457
7-Day Island Peak Demand Forecast:	1,670	MW	Thursday, January 19, 2017	1	3	1,420	1,318

- Notes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 - 2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Under frequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
 - 3. As of 0800 Hours.
 - 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 - 5. Gross output from all Island sources (including Note 4).
 - 6. NLH Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Vale capacity assistance (when applicable), and Wind Generation.
 - 7. Adjusted for CBP&P and Praxair interruptible load as well as the impact of voltage reduction, when applicable.

Island Peak Demand Information						
Previous Day Actual Peak and Current Day Forecast Peak						
Thu, Jan 12, 2017	Actual Island Peak Demand ⁸	08:40	1,350 MW			
Fri, Jan 13, 2017	Forecast Island Peak Demand		1,300 MW			