


**Newfoundland Labrador Hydro (NLH)
Supply and Demand Status Report Filed Friday, January 27, 2017**

**Section 1
Island Interconnected System Supply and Demand
Actual 24 Hour System Performance For Thursday, January 26, 2017**



Supply Notes For January 26, 2017

1,2

- A As of 1556 hours, January 20, 2017, Holyrood Unit 2 available at 150 MW (170 MW).
 B As of 1047 hours, January 24, 2017, Stephenville Gas Turbine available at 25 MW (50 MW).
 C At 2125 hours, January 26, 2017, Holyrood Unit 1 unavailable due to planned outage, 145 MW (170 MW).

**Section 2
Island Interconnected Supply and Demand**

Fri, Jan 27, 2017	Island System Outlook ³	Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)	
			Morning	Evening	Forecast	Adjusted ⁷
Available Island System Supply: ⁵	1,845 MW	Friday, January 27, 2017	3	-2	1,390	1,283
NLH Generation: ⁴	1,480 MW	Saturday, January 28, 2017	-1	-2	1,415	1,307
NLH Power Purchases: ⁶	155 MW	Sunday, January 29, 2017	-2	-2	1,445	1,337
Other Island Generation:	210 MW	Monday, January 30, 2017	-2	-3	1,495	1,387
Current St. John's Temperature:	4 °C	Tuesday, January 31, 2017	-5	-5	1,520	1,411
Current St. John's Windchill:	N/A °C	Wednesday, February 01, 2017	-7	-5	1,565	1,456
7-Day Island Peak Demand Forecast:	1,565 MW	Thursday, February 02, 2017	-1	-5	1,525	1,416

Supply Notes For January 27, 2017

3

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Under frequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
 3. As of 0800 Hours.
 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 5. Gross output from all Island sources (including Note 4).
 6. NLH Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Vale capacity assistance (when applicable), and Wind Generation.
 7. Adjusted for CBP&P, Praxair and Vale interruptible load as well as the impact of voltage reduction, when applicable.

**Section 3
Island Peak Demand Information
Previous Day Actual Peak and Current Day Forecast Peak**

Thu, Jan 26, 2017	Actual Island Peak Demand ⁸	17:55	1,356 MW
Fri, Jan 27, 2017	Forecast Island Peak Demand		1,390 MW

- Notes: 8. Island Demand is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).