

Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Friday, July 14, 2017

F As of 0604 hours, July 03, 2017, Bay d'Espoir Unit 2 unavailable due to planned outage (76. 5 MW).

As of 0004 hours, July 03, 2017, Bay a Espon offic 2 diavailable due to planned outage (70. 3 MM)
As of 1018 hours, July 07, 2017, Granite Canal Unit unavailable due to planned outage (40 MW).

As of 1018 hours, July 07, 2017, Granite Canar Onit unavailable due to planned outage (40 MM)
H As of 1314 hours, July 11, 2017, St. Anthony Diesel Plant available at 8.85 MW (9.7 MW).

Section 2 Island Interconnected Supply and Demand								
Fri, Jul 14, 2017 Island S	System Outlook ³		Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW		
	ystem out	oon	Seven-Day Torecast	Morning	Evening	Forecast		
Available Island System Supply: ⁵	1,465	MW	Friday, July 14, 2017	16	17	770		
NLH Generation: ⁴	1,150	MW	Saturday, July 15, 2017	18	16	740		
NLH Power Purchases: ⁶	110	MW	Sunday, July 16, 2017	14	17	755		
Other Island Generation:	205	MW	Monday, July 17, 2017	18	17	780		
Current St. John's Temperature:	15	°C	Tuesday, July 18, 2017	19	20	790		
Current St. John's Windchill:	N/A	°C	Wednesday, July 19, 2017	16	18	775		
7-Day Island Peak Demand Forecast:	790	MW	Thursday, July 20, 2017	16	18	790		

- Notes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 - 2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Under frequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
 - 3. As of 0800 Hours.
 - 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 - 5. Gross output from all Island sources (including Note 4).
 - 6. NLH Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Vale capacity assistance (when applicable), and Wind Generation.

Section 3 Island Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak								
Thu, Jul 13, 2017	Actual Island Peak Demand ⁸	11:45	752 MW					
Fri, Jul 14, 2017	Forecast Island Peak Demand		770 MW					