

Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Monday, August 07, 2017

- As of 1018 hours, July 07, 2017, Granite Canal Unit unavailable due to planned outage (40 MW).
- D As of 1314 hours, July 11, 2017, St. Anthony Diesel Plant available at 8.85 MW (9.7 MW).
- Ε As of 1058 hours, July 23, 2017, Bay d'Espoir Unit 1 unavailable due to planned outage (76. 5 MW).
- F As of 0827 hours, July 31, 2017, Holyrood Unit 2 unavailable due to planned outage 165 MW (170 MW).
- G As of 0827 hours, July 31, 2017, Holyrood Unit 3 unavailable due to planned outage (150 MW).
- At 1250 hours, August 06, 2017, Upper Salmon Unit unavailable due to planned outage (84 MW) н

Section 2 Island Interconnected Supply and Demand							
Mon, Aug 07, 2017 Island S	System Outlook ³		Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)	
				Morning	Evening	Forecast	
Available Island System Supply: ⁵	1,285	MW	Monday, August 07, 2017	15	16	815	
NLH Generation: ⁴	970	MW	Tuesday, August 08, 2017	16	18	785	
NLH Power Purchases: ⁶	120	MW	Wednesday, August 09, 2017	13	14	795	
Other Island Generation:	195	MW	Thursday, August 10, 2017	16	17	800	
Current St. John's Temperature:	14	°C	Friday, August 11, 2017	17	18	785	
Current St. John's Windchill:	N/A	°C	Saturday, August 12, 2017	16	16	775	
7-Day Island Peak Demand Forecast:	815	MW	Sunday, August 13, 2017	16	16	770	

At 0714 hours, August 07, 2017, Paradise River Unit unavailable (8 MW).

- Notes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 - 2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Under frequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
 - 3. As of 0800 Hours.
 - 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 - 5. Gross output from all Island sources (including Note 4).
 - 6. NLH Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Vale capacity assistance (when applicable), and Wind Generation.

Section 3 Island Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak								
Sun, Aug 06, 2017	Actual Island Peak Demand ⁸	21:00	709 MW					
Mon, Aug 07, 2017	Forecast Island Peak Demand		815 MW					