


Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Monday, August 21, 2017

Section 1 Island Interconnected System Supply and Demand Actual 24 Hour System Performance For Sunday, August 20, 2017



Supply Notes For August 20, 2017

- A** As of 1858 hours, June 22, 2017, Stephenville Gas Turbine available at 25 MW (50 MW).
B As of 0938 hours, June 23, 2017, Holyrood Unit 1 unavailable due to planned outage 120 MW (170 MW).
C As of 0827 hours, July 31, 2017, Holyrood Unit 2 unavailable due to planned outage 165 MW (170 MW).
D As of 1250 hours, August 06, 2017, Upper Salmon Unit unavailable due to planned outage (84 MW).
E As of 1333 hours, August 17, 2017, Hardwoods Gas Turbine available at 25 MW (50 MW).

Section 2 Island Interconnected Supply and Demand

Mon, Aug 21, 2017		Island System Outlook ³		Seven-Day Forecast		Temperature (°C)		Island System Daily Peak Demand (MW)	
						Morning	Evening	Forecast	
Available Island System Supply: ⁵	1,530	MW		Monday, August 21, 2017		18	19	810	
NLH Generation: ⁴	1,220	MW		Tuesday, August 22, 2017		17	21	795	
NLH Power Purchases: ⁶	120	MW		Wednesday, August 23, 2017		15	19	795	
Other Island Generation:	190	MW		Thursday, August 24, 2017		20	19	805	
Current St. John's Temperature:	16	°C		Friday, August 25, 2017		19	17	795	
Current St. John's Windchill:	N/A	°C		Saturday, August 26, 2017		16	13	775	
7-Day Island Peak Demand Forecast:	850	MW		Sunday, August 27, 2017		10	10	850	

Supply Notes For August 21, 2017

- Notes:**
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Under frequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
 3. As of 0800 Hours.
 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 5. Gross output from all Island sources (including Note 4).
 6. NLH Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Vale capacity assistance (when applicable), and Wind Generation.

Section 3 Island Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak

Sun, Aug 20, 2017	Actual Island Peak Demand ⁸	12:00	773 MW
Mon, Aug 21, 2017	Forecast Island Peak Demand		810 MW

- Notes:** 8. Island Demand is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).