


Newfoundland Labrador Hydro (NLH)

Supply and Demand Status Report Filed Tuesday, August 29, 2017

Section 1 Island Interconnected System Supply and Demand Actual 24 Hour System Performance For Monday, August 28, 2017



Supply Notes For August 28, 2017

- A** As of 1858 hours, June 22, 2017, Stephenville Gas Turbine available at 25 MW (50 MW).
B As of 0938 hours, June 23, 2017, Holyrood Unit 1 unavailable due to planned outage 120 MW (170 MW).
C As of 0827 hours, July 31, 2017, Holyrood Unit 2 unavailable due to planned outage 165 MW (170 MW).
D As of 0828 hours, August 27, 2017, Bay d'Espoir Unit 7 unavailable due to planned outage (154.4 MW).
E At 0927 hours, August 28, 2017, Hardwoods Gas Turbine unavailable due to a planned outage 25 MW (50 MW).

Section 2 Island Interconnected Supply and Demand

Tue, Aug 29, 2017		Island System Outlook ³	Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW) Forecast
				Morning	Evening	
Available Island System Supply: ⁵	1,400	MW	Tuesday, August 29, 2017	12	12	790
NLH Generation: ⁴	1,125	MW	Wednesday, August 30, 2017	13	13	790
NLH Power Purchases: ⁶	90	MW	Thursday, August 31, 2017	12	13	820
Other Island Generation:	185	MW	Friday, September 01, 2017	11	12	830
Current St. John's Temperature:	11	°C	Saturday, September 02, 2017	11	9	855
Current St. John's Windchill:	N/A	°C	Sunday, September 03, 2017	13	13	795
7-Day Island Peak Demand Forecast:	855	MW	Monday, September 04, 2017	14	14	795

Supply Notes For August 29, 2017

- Notes:**
- Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 - Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Under frequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
 - As of 0800 Hours.
 - Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 - Gross output from all Island sources (including Note 4).
 - NLH Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Vale capacity assistance (when applicable), and Wind Generation.

Section 3 Island Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak

Mon, Aug 28, 2017	Actual Island Peak Demand ⁸	11:25	776 MW
Tue, Aug 29, 2017	Forecast Island Peak Demand		790 MW

- Notes:** 8. Island Demand is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).