

Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Tuesday, December 05, 2017

As of 1510 hours, November 04, 2017, Bay d'Espoir Unit 1 unavailable (76.5 MW).

В As of 1510 hours, November 04, 2017, Bay d'Espoir Unit 2 unavailable (76.5 MW).

С As of 1908 hours, November 24, 2017, Holyrood Unit 2 available at 160 MW (170 MW).

D As of 0852 hours, December 02, 2017, Stephenville Gas Turbine available at 38 MW (50 MW).

At 1508 hours, December 04, 2017, Holyrood Unit 1 available at 150 MW (170 MW)

| Гие, Dec 05, 2017 Island S | d System Outlook ³ | | and Interconnected Supply and Den Seven-Day Forecast | Temperature (°C) | | Island System Daily Peak Demand (MW) | |
|--|-------------------------------|----|---|---------------------|---------|---|-----------------------|
| | | | | Morning | Evening | Forecast | Adjusted ⁷ |
| Available Island System Supply: ⁵ | 1,775 | MW | Tuesday, December 05, 2017 | 1 | 0 | 1,390 | 1,283 |
| NLH Generation: ⁴ | 1,500 | MW | Wednesday, December 06, 2017 | 0 | 1 | 1,320 | 1,214 |
| NLH Power Purchases: ⁶ | 100 | MW | Thursday, December 07, 2017 | 4 | 4 | 1,305 | 1,199 |
| Other Island Generation: | 175 | MW | Friday, December 08, 2017 | -2 | 1 | 1,325 | 1,219 |
| Current St. John's Temperature: | 0 | °C | Saturday, December 09, 2017 | 0 | 2 | 1,335 | 1,228 |
| Current St. John's Windchill: | N/A | °C | Sunday, December 10, 2017 | 3 | 3 | 1,260 | 1,154 |
| 7-Day Island Peak Demand Forecast: | 1,390 | MW | Monday, December 11, 2017 | 9 | 3 | 1,285 | 1,179 |

- Notes: Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 - 2. Due to the Island Interconnected System being isolated from the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Under frequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.
 - 3. As of 0800 Hours.
 - 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 - 5. Gross output from all Island sources (including Note 4).
 - 6. NLH Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Vale capacity assistance (when applicable), and Wind Generation.
 - 7. Adjusted for CBP&P and Vale and Praxair interruptible load and the impact of voltage reduction, when applicable.

| | Section | n 3 | | | | |
|--|--|----------------|----------|--|--|--|
| | Island Peak Demar | nd Information | | | | |
| Previous Day Actual Peak and Current Day Forecast Peak | | | | | | |
| Mon, Dec 04, 2017 | Actual Island Peak Demand ⁸ | 17:00 | 1,343 MW | | | |
| Tue, Dec 05, 2017 | Forecast Island Peak Demand | | 1,390 MW | | | |