


Newfoundland Labrador Hydro (NLH)
Supply and Demand Status Report Filed Monday, August 27, 2018

Section 1
Island Interconnected System Supply, Demand & Exports
Actual 24 Hour System Performance For Friday, August 24, 2018



Supply Notes For August 24, 20181,2

A

As of 1438 hours, May 22, 2018, Holyrood Unit 2 unavailable due to planned outage 70 MW (170 MW).

B

As of 0801 hours, July 19, 2018, Holyrood Unit 3 removed from service for economic dispatch 110 MW (150 MW).

C

As of 1000 hours, July 27, 2018, Holyrood Unit 1 unavailable due to planned outage 88 MW (170 MW).

D

As of 0823 hours, August 06, 2018, Cat Arm unit 1 unavailable due to planned outage 50 MW (67 MW).

E

As of 1000 hours, August 06, 2018, Cat Arm unit 2 unavailable due to planned outage (67 MW).

F

As of 1609 hours, August 07, 2018, Stephenville Gas Turbine available at 25 MW (50 MW).

G

As of 1118 hours, August 21, 2018, Holyrood Gas Turbine unavailable due to planned outage (123.5 MW).

H

At 0651 hours, August 24, 2018, Granite Canal Unit available at 37 MW (40 MW).

Section 2
Island Interconnected Supply and Demand

Sat, Aug 25, 2018				Island System Outlook ³		Seven-Day Forecast		Temperature (°C)		Island System Daily Peak Demand (MW)	
								Morning	Evening	Forecast	Adjusted ⁷
Available Island System Supply: ⁵				1,210	MW	Saturday, August 25, 2018		19	21	735	735
NLH Island Generation: ⁴				915	MW	Sunday, August 26, 2018		20	21	760	760
NLH Island Power Purchases: ⁶				110	MW	Monday, August 27, 2018		16	18	805	805
Other Island Generation:				185	MW	Tuesday, August 28, 2018		17	20	805	805
ML/LIL Imports:				-	MW	Wednesday, August 29, 2018		18	14	795	795
Current St. John's Temperature & Windchill: 17 °C				N/A	°C	Thursday, August 30, 2018		14	18	805	805
7-Day Island Peak Demand Forecast:				805	MW	Friday, August 31, 2018		15	12	805	805

Supply Notes For August 25, 20183

Notes:

1.

Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.

2.

Due to the Island System having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units some customer's load must be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding, is necessary to ensure the integrity and reliability of system equipment. Under frequency events typically occur 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes.

3.

As of 0800 Hours.

4.

Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).

5.

Gross output from all Island sources (including Note 4).

6.

NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation, Vale capacity assistance (when applicable).

7.

Adjusted for CBPP, Vale and Praxair interruptible load, Maritime Link and Labrador-Island Link exports and the impact of voltage reduction, when applicable.

Section 3
Island Peak Demand Information
Previous Day Actual Peak and Current Day Forecast Peak

Fri, Aug 24, 2018	Actual Island Peak Demand ⁸	11:55	749 MW
Sat, Aug 25, 2018	Forecast Island Peak Demand		735 MW

Notes:

8.

Island Demand / LIL / ML Exports (where applicable) is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).