


Newfoundland Labrador Hydro (NLH)

Supply and Demand Status Report Filed Tuesday, November 13, 2018



Supply Notes For November 11, 2018

1,2

A    As of 2017 hours, November 03, 2018, Holyrood Unit 1 unavailable due to planned outage 40 MW (170 MW).

B    As of 0729 hours, November 09, 2018, Stephenville Gas Turbine available at 25 MW (50 MW).

Section 2 Island Interconnected Supply and Demand										
Mon, Nov 12, 2018  Island System Outlook <sup>3</sup>					Seven-Day Forecast		Temperature (°C)		Island System Daily Peak Demand (MW)	
							Morning	Evening	Forecast	Adjusted <sup>7</sup>
Available Island System Supply: <sup>5</sup>			1,830	MW	Monday, November 12, 2018		2	1	1,270	1,175
NLH Island Generation: <sup>4</sup>			1,500	MW	Tuesday, November 13, 2018		1	1	1,305	1,210
NLH Island Power Purchases: <sup>6</sup>			150	MW	Wednesday, November 14, 2018		3	2	1,360	1,264
Other Island Generation:			180	MW	Thursday, November 15, 2018		2	2	1,410	1,314
ML/LIL Imports:			-	MW	Friday, November 16, 2018		0	-1	1,315	1,220
Current St. John's Temperature & Windchill:			1 °C	N/A °C	Saturday, November 17, 2018		2	3	1,280	1,185
7-Day Island Peak Demand Forecast:			1,410	MW	Sunday, November 18, 2018		4	2	1,205	1,111

Supply Notes For November 12, 2018

3

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.

2. Due to the Island system having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units there may be a requirement for some customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes. With the activation of the Maritime Link frequency controller during the winter of 2018, UFLS events have occurred less frequently.

3. As of 0800 Hours.

4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).

5. Gross output from all Island sources (including Note 4).

6. NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).

7. Adjusted for curtailable load, market activities and the impact of voltage reduction when applicable.

Section 3

Island Peak Demand Information

Previous Day Actual Peak and Current Day Forecast Peak

Sun, Nov 11, 2018	Actual Island Peak Demand <sup>8</sup>	17:00	1,148 MW
Mon, Nov 12, 2018	Forecast Island Peak Demand		1,270 MW

Notes: 8. Island Demand / LIL / ML Exports (where applicable) is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).