
Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Monday, January 11, 2021

Section 1 Island Interconnected System Supply, Demand & Exports Actual 24 Hour System Performance For Saturday, January 09, 2021



Supply Notes For January 09, 2021

1,2

3

As of 1433 hours, January 05, 2020, Holyrood Unit 3 available but not operating (150 MW).

At 1549 hours, January 09, 2021, Hawkes Bay Diesel Plant available at full capacity (5 MW).

Section 2

Island Interconnected Supply and Demand

Sun, Jan 10, 2021	Island System Outlook ³			Seven-Day Forecast		Temperature (°C)		Island System Daily Peak Demand (MW)	
					Morning	Evening	Forecast	Adjusted ⁷	
Available Island System Supply: ⁵		2,060	MW	Sunday, January 10, 2021	0	0	1,350	1,246	
NLH Island Generation: ⁴		1,545	MW	Monday, January 11, 2021	-2	-4	1,425	1,321	
NLH Island Power Purchases: ⁶		130	MW	Tuesday, January 12, 2021	-5	-2	1,375	1,271	
Other Island Generation:		245	MW	Wednesday, January 13, 2021	-1	-2	1,335	1,232	
ML/LIL Imports:		140	MW	Thursday, January 14, 2021	-3	-1	1,340	1,237	
Current St. John's Temperature & Windchill:	-1 °C	-8	°C	Friday, January 15, 2021	0	-1	1,290	1,187	
7-Day Island Peak Demand Forecast:		1,425	MW	Saturday, January 16, 2021	1	6	1,235	1,133	

Supply Notes For January 10, 2021

Notes:

- 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
- 2. Due to the Island system having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units there may be a requirement for some customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes. With the activation of the Maritime Link frequency controller during the winter of 2018, UFLS events have occurred less frequently.
- 3. As of 0800 Hours.
- 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
- 5. Gross output from all Island sources (including Note 4).
- 6. NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
- 7. Adjusted for curtailable load, market activities and the impact of voltage reduction when applicable.

Section 3 Island Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak Sat, Jan 09, 2021 Actual Island Peak Demand⁸ Sun, Jan 10, 2021 Forecast Island Peak Demand 1,350 MW

Notes: 8. Island Demand / LIL / ML Exports (where applicable) is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).