


**Newfoundland Labrador Hydro (NLH)
Supply and Demand Status Report Filed Thursday, February 04, 2021**

**Section 1
Island Interconnected System Supply, Demand & Exports
Actual 24 Hour System Performance For Wednesday, February 03, 2021**



Supply Notes For February 03, 2021

1,2

**Section 2
Island Interconnected Supply and Demand**

Thu, Feb 04, 2021	Island System Outlook ³		Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)	
				Morning	Evening	Forecast	Adjusted ⁷
Available Island System Supply: ⁵	2,181	MW	Thursday, February 04, 2021	5	1	1,130	1,029
NLH Island Generation: ⁴	1,695	MW	Friday, February 05, 2021	3	0	1,175	1,073
NLH Island Power Purchases: ⁶	115	MW	Saturday, February 06, 2021	0	2	1,240	1,138
Other Island Generation:	245	MW	Sunday, February 07, 2021	0	-2	1,300	1,197
ML/LIL Imports:	126	MW	Monday, February 08, 2021	-4	-3	1,315	1,212
Current St. John's Temperature & Windchill:	6 °C	N/A	Tuesday, February 09, 2021	-4	-3	1,320	1,217
7-Day Island Peak Demand Forecast:	1,395	MW	Wednesday, February 10, 2021	-5	-4	1,395	1,291

Supply Notes For February 04, 2021

3

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. Due to the Island system having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units there may be a requirement for some customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes. With the activation of the Maritime Link frequency controller during the winter of 2018, UFLS events have occurred less frequently.
 3. As of 0800 Hours.
 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 5. Gross output from all Island sources (including Note 4).
 6. NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 7. Adjusted for curtailable load, market activities and the impact of voltage reduction when applicable.

**Section 3
Island Peak Demand Information
Previous Day Actual Peak and Current Day Forecast Peak**

Wed, Feb 03, 2021	Actual Island Peak Demand ⁸	10:00	1,300 MW
Thu, Feb 04, 2021	Forecast Island Peak Demand		1,130 MW

Notes: 8. Island Demand / LIL / ML Exports (where applicable) is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).