


**Newfoundland Labrador Hydro (NLH)
Supply and Demand Status Report Filed Monday, March 29, 2021**

**Section 1
Island Interconnected System Supply, Demand & Exports
Actual 24 Hour System Performance For Friday, March 26, 2021**



Supply Notes For March 26, 2021

1,2

A As of 1800 hours, March 24, 2021, Holyrood Unit 1 available but not operating (170 MW).

**Section 2
Island Interconnected Supply and Demand**

Sat, Mar 27, 2021	Island System Outlook ³		Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)	
				Morning	Evening	Forecast	Adjusted ⁷
Available Island System Supply: ⁵	2,057	MW	Saturday, March 27, 2021	-1	-2	1,340	1,237
NLH Island Generation: ⁴	1,525	MW	Sunday, March 28, 2021	-3	-4	1,305	1,202
NLH Island Power Purchases: ⁶	135	MW	Monday, March 29, 2021	-2	3	1,325	1,222
Other Island Generation:	250	MW	Tuesday, March 30, 2021	0	-4	1,225	1,123
ML/LIL Imports:	147	MW	Wednesday, March 31, 2021	-5	-3	1,310	1,207
Current St. John's Temperature & Windchill:	-1 °C	-9 °C	Thursday, April 01, 2021	-3	2	1,225	1,123
7-Day Island Peak Demand Forecast:	1,340	MW	Friday, April 02, 2021	1	2	1,155	1,123

Supply Notes For March 27, 2021

3

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. Due to the Island system having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units there may be a requirement for some customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes. With the activation of the Maritime Link frequency controller during the winter of 2018, UFLS events have occurred less frequently.
 3. As of 0800 Hours.
 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 5. Gross output from all Island sources (including Note 4).
 6. NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 7. Adjusted for curtailable load, market activities and the impact of voltage reduction when applicable.

**Section 3
Island Peak Demand Information
Previous Day Actual Peak and Current Day Forecast Peak**

Fri, Mar 26, 2021	Actual Island Peak Demand ⁸	11:35	1,039 MW
Sat, Mar 27, 2021	Forecast Island Peak Demand		1,340 MW

Notes: 8. Island Demand / LIL / ML Exports (where applicable) is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).