


Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Monday, December 05, 2022

Section 1 Island Interconnected System Supply, Demand & Exports Actual 24 Hour System Performance For Sunday, December 04, 2022



Supply Notes For December 04, 2022

1,2

- A As of 0806 hours, November 10, 2022, St. Anthony Diesel Plant available at 8.7 MW (9.7 MW).
 B As of 0144 hours, November 24, 2022, Holyrood Unit 1 available at 80 MW (170 MW).
 C At 1222 hours, December 04, 2022, Bay d'Espoir Unit 7 available (154.4 MW).

Section 2 Island Interconnected Supply and Demand

Mon, Dec 05, 2022	Island System Outlook ³			Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)	
					Morning	Evening	Forecast	Adjusted ⁷
Available Island System Supply: ⁵	2,216	MW		Monday, December 5, 2022	2	2	1,535	1,437
NLH Island Generation: ^{4,8}	1,600	MW		Tuesday, December 6, 2022	2	2	1,265	1,170
NLH Island Power Purchases: ⁶	125	MW		Wednesday, December 7, 2022	3	3	1,245	1,151
Other Island Generation:	200	MW		Thursday, December 8, 2022	2	3	1,205	1,111
ML/LIL Imports:	291	MW		Friday, December 9, 2022	3	3	1,200	1,106
Current St. John's Temperature & Windchill:	1 °C	N/A	°C	Saturday, December 10, 2022	2	3	1,230	1,136
7-Day Island Peak Demand Forecast:	1,535	MW		Sunday, December 11, 2022	2	1	1,310	1,215

Supply Notes For December 05, 2022

3

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. Due to the Island system having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units there may be a requirement for some customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes. With the activation of the Maritime Link frequency controller during the winter of 2018, UFLS events have occurred less frequently.
 3. As of 0800 Hours.
 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 5. Gross output from all Island sources (including Note 4).
 6. NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 7. Adjusted for curtailable load, market activities and the impact of voltage reduction when applicable.
 8. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold

Section 3 Island Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak

Sun, Dec 04, 2022	Actual Island Peak Demand ⁹	17:00	1,472 MW
Mon, Dec 05, 2022	Forecast Island Peak Demand		1,535 MW

- Notes: 9. Island Demand / LIL / ML Exports (where applicable) is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).