


## Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Wednesday, December 28, 2022

### Section 1 Island Interconnected System Supply, Demand & Exports Actual 24 Hour System Performance For Saturday, December 24, 2022



Supply Notes For December 24, 2022

1,2

### Section 2 Island Interconnected Supply and Demand

Sun, Dec 25, 2022	Island System Outlook <sup>3</sup>			Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)	
					Morning	Evening	Forecast	Adjusted <sup>7</sup>
Available Island System Supply: <sup>5</sup>	2,052	MW		Sunday, December 25, 2022	1	4	1,165	1,072
NLH Island Generation: <sup>4,8</sup>	1,695	MW		Monday, December 26, 2022	2	0	1,330	1,235
NLH Island Power Purchases: <sup>6</sup>	130	MW		Tuesday, December 27, 2022	-3	0	1,525	1,427
Other Island Generation:	225	MW		Wednesday, December 28, 2022	0	-4	1,455	1,358
ML/LIL Imports:	2	MW		Thursday, December 29, 2022	-5	-3	1,430	1,333
Current St. John's Temperature & Windchill:	1 °C	N/A	°C	Friday, December 30, 2022	-3	-4	1,410	1,314
7-Day Island Peak Demand Forecast:	1,525	MW		Saturday, December 31, 2022	-6	-6	1,475	1,378

Supply Notes For December 25, 2022

3

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
  2. Due to the Island system having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units there may be a requirement for some customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes. With the activation of the Maritime Link frequency controller during the winter of 2018, UFLS events have occurred less frequently.
  3. As of 0800 Hours.
  4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
  5. Gross output from all Island sources (including Note 4).
  6. NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
  7. Adjusted for curtailable load, market activities and the impact of voltage reduction when applicable.
  8. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold.

### Section 3 Island Peak Demand Information Previous Day Actual Peak and Current Day Forecast Peak

Sat, Dec 24, 2022	Actual Island Peak Demand <sup>9</sup>	16:35	1,360 MW
Sun, Dec 25, 2022	Forecast Island Peak Demand		1,165 MW

Notes: 9. Island Demand / LIL / ML Exports (where applicable) is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).