


**Newfoundland Labrador Hydro (NLH)
Supply and Demand Status Report Filed Thursday, February 23, 2023**

**Section 1
Island Interconnected System Supply, Demand & Exports
Actual 24 Hour System Performance For Wednesday, February 22, 2023**



Supply Notes For February 22, 2023

- 1,2
A As of 1144 hours, February 16, 2023, Holyrood Unit 1 unavailable (170 MW).
B At 2345 hours, February 22, 2023, Holyrood Unit 3 available (150 MW).

**Section 2
Island Interconnected Supply and Demand**

Thu, Feb 23, 2023	Island System Outlook ³	Seven-Day Forecast	Temperature (°C)		Island System Daily Peak Demand (MW)	
			Morning	Evening	Forecast	Adjusted ⁷
Available Island System Supply: ⁵	2,316 MW	Thursday, February 23, 2023	-8	-12	1,730	1,630
NLH Island Generation: ^{4,8}	1,525 MW	Friday, February 24, 2023	-15	-12	1,840	1,740
NLH Island Power Purchases: ⁶	130 MW	Saturday, February 25, 2023	-10	-12	1,745	1,645
Other Island Generation:	230 MW	Sunday, February 26, 2023	-14	-16	1,785	1,685
ML/LIL Imports:	431 MW	Monday, February 27, 2023	-16	-12	1,845	1,745
Current St. John's Temperature & Windchill:	-8 °C -19 °C	Tuesday, February 28, 2023	-13	-10	1,755	1,655
7-Day Island Peak Demand Forecast:	1,845 MW	Wednesday, March 1, 2023	-11	-9	1,660	1,560

Supply Notes For February 23, 2023

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. The power system operators schedule outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. Due to the Island system having no synchronous connections to the larger North American grid, when there is a sudden loss of large generating units there may be a requirement for some customer's load to be interrupted for short periods to bring generation output equal to customer demand. This automatic action of power system protection, referred to as under frequency load shedding (UFLS), is necessary to ensure the integrity and reliability of system equipment. Under frequency events have typically occurred 5 to 8 times per year on the Island Interconnected System and the resultant customer load interruptions are generally less than 30 minutes. With the activation of the Maritime Link frequency controller during the winter of 2018, UFLS events have occurred less frequently.
 3. As of 0800 Hours.
 4. Gross output including station service at Holyrood (24.5 MW) and improved NLH hydraulic output due to water levels (35 MW).
 5. Gross output from all Island sources (including Note 4).
 6. NLH Island Power Purchases include: CBPP Co-Gen, Nalcor Exploits, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 7. Adjusted for curtailable load, market activities and the impact of voltage reduction when applicable.
 8. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold

**Section 3
Island Peak Demand Information
Previous Day Actual Peak and Current Day Forecast Peak**

Wed, Feb 22, 2023	Actual Island Peak Demand ⁹	12:05	1,627 MW
Thu, Feb 23, 2023	Forecast Island Peak Demand		1,730 MW

- Notes: 9. Island Demand / LIL / ML Exports (where applicable) is supplied by NLH generation and purchases, plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).