


Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Friday, July 05, 2024

Section 1 Island Interconnected System - Supply, Demand & Exports Actual 24 Hour System Performance For Thursday, July 04, 2024



Island Supply Notes For July 04, 2024

- A As of 2059 hours, July 13, 2023, Stephenville Gas Turbine unavailable due to forced outage (50 MW).
- B As of 1011 hours, April 12, 2024, Holyrood Unit 1 unavailable due to planned outage (170 MW).
- C As of 1038 hours, May 20, 2024, Bay d'Espoir Unit 1 unavailable due to planned outage (76.5 MW).
- D As of 0700 hours, May 26, 2024, Holyrood Unit 3 unavailable due to planned outage (150 MW).
- E As of 0510 hours, May 27, 2024, Cat Arm Unit 1 available at 60 MW due to forced derating (67 MW).
- F As of 0859 hours, May 30, 2024, Holyrood Unit 2 available but not operating (170 MW).
- G As of 1255 hours, May 31, 2024, Labrador Island Link available at 450 MW due to forced derating (700 MW) - Bipole.
- H As of 1346 hours, June 16, 2024, Granite Canal Unit unavailable due to planned outage (40 MW).
- I At 0659 hours, July 04, 2024, Bay d'Espoir Unit 5 unavailable due to planned outage (76.5 MW).
- J At 1345 hours, July 04, 2024, Bay d'Espoir Unit 5 available (76.5 MW).
- K At 1856 hours, July 04, 2024, Bay d'Espoir Unit 6 unavailable due to planned outage (76.5 MW).

Section 2 Island Interconnected System - Supply, Demand & Outlook

Fri, Jul 05, 2024	Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast ⁸	Adjusted ⁶
Island System Supply: ⁴	1,280 MW	Friday, July 5, 2024	760	710
NLH Island Generation: ^{3,7}	955 MW	Saturday, July 6, 2024	690	640
NLH Island Power Purchases: ⁵	90 MW	Sunday, July 7, 2024	720	670
NP and CBPP Owned Generation:	195 MW	Monday, July 8, 2024	760	710
LIL Net Imports to Island: ⁹	40 MW	Tuesday, July 9, 2024	760	710
		Wednesday, July 10, 2024	760	710
7-Day Island Peak Demand Forecast:	765 MW	Thursday, July 11, 2024	765	715

Island Supply Notes For July 05, 2024

- Notes:
1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. As of 0800 Hours.
 3. Gross continuous unit output.
 4. Gross output from all Island sources (including Note 4).
 5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
 7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
 8. Does not include ML Exports.
 9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3 Island Peak Demand and Exports Information Previous Day Actual Peak and Current Day Forecast Peak

Thu, Jul 04, 2024	Island Peak Demand ¹⁰	12:40	734 MW
	Exports at Peak		380 MW
	LIL Net Imports to Island		994 MWh
Fri, Jul 05, 2024	Forecast Island Peak Demand		760 MW

- Notes: 10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).