


Newfoundland Labrador Hydro (NLH)  
Supply and Demand Status Report Filed Friday, September 26, 2025



- Island Supply Notes For September 25, 2025<sup>1</sup>
- A

As of 0800 hours, March 30, 2025, Holyrood Unit 3 unavailable due to planned outage 130 MW (150 MW).
- B

As of 0823 hours, March 31, 2025, Bay d'Espoir Unit 1 unavailable due to planned outage (76.5 MW).
- C

As of 0823 hours, March 31, 2025, Bay d'Espoir Unit 2 unavailable due to planned outage (76.5 MW).
- D

As of 2000 hours, September 13, 2025, Holyrood Unit 2 unavailable due to forced extension to planned outage 115 MW (170 MW).
- E

As of 1312 hours, September 17, 2025, St. Anthony Diesel Plant unavailable due to a planned outage (9.7 MW).
- F

As of 0720 hours, September 21, 2025, Labrador Island Link unavailable due to a planned outage (700 MW).
- G

At 2325 hours, September 25, 2025, Holyrood Unit 1 unavailable due to a forced outage 100 MW (170 MW).

Section 2 Island Interconnected System - Supply, Demand & Outlook				
Fri, Sep 26, 2025	Island System Outlook <sup>2</sup>	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast <sup>8</sup>	Adjusted <sup>6</sup>
Island System Supply: <sup>4</sup> NLH Island Generation: <sup>3,7</sup> NLH Island Power Purchases: <sup>5</sup> NP and CBPP Owned Generation: LIL/ML Net Imports to Island: <sup>9</sup>	1,533 MW	Friday, September 26, 2025	785	735
	1,040 MW	Saturday, September 27, 2025	770	720
	170 MW	Sunday, September 28, 2025	790	740
	195 MW	Monday, September 29, 2025	815	765
	128 MW	Tuesday, September 30, 2025	800	750
7-Day Island Peak Demand Forecast:	955 MW	Wednesday, October 1, 2025	895	845
		Thursday, October 2, 2025	955	905

- Island Supply Notes For September 26, 2025
- Notes: 

1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.

2. As of 0800 Hours.

3. Gross continuous unit output.

4. Gross output from all Island sources (including Note 3).

5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).

6. Adjusted for interruptible load and the impact of voltage reduction when applicable.

7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.

8. Does not include ML Exports.

9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3 Island Peak Demand and Exports Information Previous Day Actual Peak and Current Day Forecast Peak			
Thu, Sep 25, 2025	Island Peak Demand <sup>10</sup>	7:45	836 MW
	Exports at Peak		0 MW
	LIL Net Imports to Island		0 MWh
Fri, Sep 26, 2025	Forecast Island Peak Demand		785 MW
Notes: 10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).			