


Newfoundland Labrador Hydro (NLH)

Supply and Demand Status Report Filed Monday, September 29, 2025



Island Supply Notes For September 27, 2025¹

A

As of 0800 hours, March 30, 2025, Holyrood Unit 3 unavailable due to planned outage 130 MW (150 MW).

B

As of 0823 hours, March 31, 2025, Bay d'Espoir Unit 1 unavailable due to planned outage (76.5 MW).

C

As of 0823 hours, March 31, 2025, Bay d'Espoir Unit 2 unavailable due to planned outage (76.5 MW).

D

As of 2000 hours, September 13, 2025, Holyrood Unit 2 unavailable due to forced extension to planned outage 115 MW (170 MW).

E

As of 1312 hours, September 17, 2025, St. Anthony Diesel Plant unavailable due to a planned outage (9.7 MW).

F

As of 0720 hours, September 21, 2025, Labrador Island Link unavailable due to a planned outage (700 MW).

G

As of 1823 hours, September 26, 2025, Holyrood Unit 1 available at 100 MW due to forced derating (170 MW).

Section 2				
Island Interconnected System - Supply, Demand & Outlook				
Sun, Sep 28, 2025	Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast ⁸	Adjusted ⁶
Island System Supply: ⁴ NLH Island Generation: ^{3,7} NLH Island Power Purchases: ⁵ NP and CBPP Owned Generation: LIL/ML Net Imports to Island: ⁹	1,645 MW	Sunday, September 28, 2025	775	725
	1,140 MW	Monday, September 29, 2025	820	770
	170 MW	Tuesday, September 30, 2025	840	790
	205 MW	Wednesday, October 1, 2025	900	850
	130 MW	Thursday, October 2, 2025	990	940
7-Day Island Peak Demand Forecast:	995 MW	Friday, October 3, 2025	995	945
		Saturday, October 4, 2025	830	780

Island Supply Notes For September 28, 2025

Notes:

1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.

2. As of 0800 Hours.

3. Gross continuous unit output.

4. Gross output from all Island sources (including Note 3).

5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).

6. Adjusted for interruptible load and the impact of voltage reduction when applicable.

7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.

8. Does not include ML Exports.

9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3			
Island Peak Demand and Exports Information			
Previous Day Actual Peak and Current Day Forecast Peak			
Sat, Sep 27, 2025	Island Peak Demand ¹⁰	11:50	735 MW
	Exports at Peak		0 MW
	LIL Net Imports to Island		0 MWh
Sun, Sep 28, 2025	Forecast Island Peak Demand		775 MW
Notes: 10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).			