


Newfoundland Labrador Hydro (NLH) Supply and Demand Status Report Filed Wednesday, November 05, 2025

Section 1 Island Interconnected System - Supply, Demand & Exports Actual 24 Hour System Performance For Tuesday, November 04, 2025



Island Supply Notes For November 04, 2025 ¹

- | | |
|---|--|
| A | As of 0800 hours, March 30, 2025, Holyrood Unit 3 unavailable due to planned outage 130 MW (150 MW). |
| B | As of 0823 hours, March 31, 2025, Bay d'Espoir Unit 1 unavailable due to planned outage (76.5 MW). |
| C | As of 0823 hours, March 31, 2025, Bay d'Espoir Unit 2 unavailable due to planned outage (76.5 MW). |
| D | As of 1502 hours, October 09, 2025, Holyrood Unit 1 available at 100 MW due to forced derating (170 MW). |
| E | As of 1405 hours, October 23, 2025, Holyrood Unit 2 available at 163 MW due to forced derating (170 MW). |
| F | As of 1600 hours, October 27, 2025, Holyrood Gas Turbine unavailable due to forced outage (123.5 MW). |
| G | As of 1320 hours, November 01, 2025, St. Anthony Diesel Plant available at 5.7 MW due to forced derating (9.7 MW). |
| H | As of 0846 hours, November 02, 2025, Hinds Lake Unit unavailable due to planned outage (75 MW). |

Section 2 Island Interconnected System - Supply, Demand & Outlook

Wed, Nov 05, 2025		Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
				Forecast ⁸	Adjusted ⁶
Island System Supply: ⁴	1,475	MW	Wednesday, November 5, 2025	1,060	968
NLH Island Generation: ^{3,7}	1,110	MW	Thursday, November 6, 2025	990	899
NLH Island Power Purchases: ⁵	55	MW	Friday, November 7, 2025	1,080	988
NP and CBPP Owned Generation:	120	MW	Saturday, November 8, 2025	1,020	928
LIL/ML Net Imports to Island: ⁹	190	MW	Sunday, November 9, 2025	920	829
7-Day Island Peak Demand Forecast:	1,080	MW	Monday, November 10, 2025	995	903
			Tuesday, November 11, 2025	955	864

Island Supply Notes For November 05, 2025

Notes:

1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
2. As of 0800 Hours.
3. Gross continuous unit output.
4. Gross output from all Island sources (including Note 3).
5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
8. Does not include ML Exports.
9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3 Island Peak Demand and Exports Information Previous Day Actual Peak and Current Day Forecast Peak
--

Tue, Nov 04, 2025	Island Peak Demand ¹⁰	16:45	1,060 MW
	Exports at Peak		209 MW
	LIL Net Imports to Island		3,635 MWh
Wed, Nov 05, 2025	Forecast Island Peak Demand		1,060 MW

Notes: 10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).