


Newfoundland Labrador Hydro (NLH)
Supply and Demand Status Report Filed Monday, November 17, 2025

Section 1
Island Interconnected System - Supply, Demand & Exports
Actual 24 Hour System Performance For Sunday, November 16, 2025



Island Supply Notes For November 16, 2025¹

A As of 0800 hours, March 30, 2025, Holyrood Unit 3 unavailable due to planned outage 130 MW (150 MW).

B As of 0823 hours, March 31, 2025, Bay d'Espoir Unit 1 unavailable due to planned outage (76.5 MW).

C As of 0823 hours, March 31, 2025, Bay d'Espoir Unit 2 unavailable due to planned outage (76.5 MW).

D As of 1502 hours, October 09, 2025, Holyrood Unit 1 available at 100 MW due to forced derating (170 MW).

E As of 0846 hours, November 02, 2025, Hinds Lake Unit unavailable due to planned outage (75 MW).

F As of 1400 hours, November 04, 2025, St. Anthony Diesel Plant available at 7.7 MW due to forced derating (9.7 MW).

G As of 0817 hours, November 14, 2025, Bay d'Espoir Unit 5 unavailable due to planned outage (76.5 MW).

H As of 0817 hours, November 14, 2025, Bay d'Espoir Unit 6 unavailable due to planned outage (76.5 MW).

I At 2145 hours, November 16, 2025, Labrador Island Link available at 450 MW due to forced derating (700 MW) - Monopole.

Section 2
Island Interconnected System - Supply, Demand & Outlook

Mon, Nov 17, 2025	Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)	
			Forecast ⁸	Adjusted ⁶
Island System Supply: ⁴ NLH Island Generation: ^{3,7} NLH Island Power Purchases: ⁵ NP and CBPP Owned Generation: LIL/ML Net Imports to Island: ⁹	1,562 MW 1,080 MW 100 MW 140 MW 242 MW	Monday, November 17, 2025	975	884
		Tuesday, November 18, 2025	1,050	958
		Wednesday, November 19, 2025	1,085	992
		Thursday, November 20, 2025	1,080	988
		Friday, November 21, 2025	1,015	923
		Saturday, November 22, 2025	1,065	973
7-Day Island Peak Demand Forecast:	1,085 MW	Sunday, November 23, 2025	1,080	988

Island Supply Notes For November 17, 2025

J At 0003 hours, November 17, 2025, Labrador Island Link available at full capacity (700 MW) - Bipole.

K At 0644 hours, November 17, 2025, Holyrood Unit 1 available at 90 MW due to forced derating (170 MW).

Notes:

1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.

2. As of 0800 Hours.

3. Gross continuous unit output.

4. Gross output from all Island sources (including Note 3).

5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).

6. Adjusted for interruptible load and the impact of voltage reduction when applicable.

7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.

8. Does not include ML Exports.

9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3
Island Peak Demand and Exports Information
Previous Day Actual Peak and Current Day Forecast Peak

Sun, Nov 16, 2025	Island Peak Demand ¹⁰	17:20	1,015 MW
	Exports at Peak		255 MW
	LIL Net Imports to Island		6,311 MWh
Mon, Nov 17, 2025	Forecast Island Peak Demand		975 MW

Notes:

10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).