


Newfoundland Labrador Hydro (NLH)
Supply and Demand Status Report Filed Tuesday, January 13, 2026

Section 1
Island Interconnected System - Supply, Demand & Exports
Actual 24 Hour System Performance For Monday, January 12, 2026



Island Supply Notes For January 12, 2026

A As of 0800 hours, March 30, 2025, Holyrood Unit 3 unavailable due to planned outage 130 MW (150 MW).
 B As of 1642 hours, December 17, 2025, Holyrood Unit 1 available at 160 MW due to forced derating (170 MW).
 C As of 1425 hours, December 22, 2025, St. Anthony Diesel Plant available at 7.7 MW due to forced derating (9.7 MW).
 D At 1304 hours, January 12, 2026, Paradise River Unit unavailable due to forced outage (8 MW).
 E At 1720 hours, January 12, 2026, Labrador Island Link available at 450 MW due to forced derating (700 MW) - Monopole.
 F At 1951 hours, January 12, 2026, Labrador Island Link unavailable due to forced outage 450 MW (700 MW).

Section 2
Island Interconnected System - Supply, Demand & Outlook

Tue, Jan 13, 2026	Island System Outlook ²	Seven-Day Forecast	Island System Daily Peak Demand (MW)
		Forecast ⁸	Adjusted ⁶
Island System Supply: ⁴	1,825 MW	Tuesday, January 13, 2026	1,380
NLH Island Generation: ^{3,7}	1,525 MW	Wednesday, January 14, 2026	1,285
NLH Island Power Purchases: ⁵	80 MW	Thursday, January 15, 2026	1,130
NP and CBPP Owned Generation:	220 MW	Friday, January 16, 2026	1,175
LIL/ML Net Imports to Island: ⁹	- MW	Saturday, January 17, 2026	1,320
7-Day Island Peak Demand Forecast:	1,380 MW	Sunday, January 18, 2026	1,255
		Monday, January 19, 2026	1,290
Island Supply Notes For January 13, 2026			

Notes: 1. Generation outages for running and corrective maintenance are included. These are not unusual for power system operations. They generally do not impact customer supply. Hydro schedules outages to system equipment whenever possible to coincide with periods when customer demands are low and sufficient supply reserves are available. However, from time to time equipment outages are necessary and reserves may be impacted.
 2. As of 0800 Hours.
 3. Gross continuous unit output.
 4. Gross output from all Island sources (including Note 3).
 5. NLH Island Power Purchases include: ML Imports, Exploits Generation, Rattle Brook, Star Lake, Wind Generation and capacity assistance (when applicable).
 6. Adjusted for interruptible load and the impact of voltage reduction when applicable.
 7. Due to limitations inherent in the design of combustion turbines, the output of combustion turbines may be reduced in the event that ambient temperatures exceed the threshold required for full rated output. This threshold is dependent on the design of each turbine.
 8. Does not include ML Exports.
 9. LIL Import sunk in the Island System. Actual LIL flows will be restricted by various system conditions including, but not limited to, Island Load, ML Exports and Avalon Unit status.

Section 3
Island Peak Demand and Exports Information
Previous Day Actual Peak and Current Day Forecast Peak

Mon, Jan 12, 2026	Island Peak Demand ¹⁰	17:20	1,421 MW
	Exports at Peak		166 MW
	LIL Net Imports to Island		2,791 MWh
Tue, Jan 13, 2026	Forecast Island Peak Demand		1,380 MW

Notes: 10. Island Demand is supplied by NLH generation and purchases, LIL Imports plus generation owned and operated by Newfoundland Power and Corner Brook Pulp & Paper (Deer Lake Power, DLP).