

1 Q. Section 7.3.1 of the ESRA Report, indicates that a firm recall power from Labrador
2 at 110 MW at Soldiers Pond would be available over the LIL for the duration of the
3 study period. Please explain any conditions assumed for the import of this power
4 beyond the LIL being in-service, i.e., does this assume that Muskrat Falls and/or the
5 Labrador Transmission Assets are in service?

6
7
8 A. This analysis assumed that Muskrat Falls was not in service for the period of
9 analysis. The Labrador Transmission Assets were in service for this analysis, as they
10 are required for the interconnection of the Labrador Island Link and Churchill Falls.