

1 Q. Further to the above, please update table on page ii of the executive summary of  
2 Teshmont Report by including all Bay d’Espoir units currently in service.

3

4

5 A. As per Hydro’s response to IC-NLH-082, it is assumed that all Bay d’Espoir units are  
6 available at full capacity in the event of contingencies such as the loss of generation  
7 at Holyrood or the loss of the HVdc links and as a result there is no update required  
8 to the table.