

- 1 Q. Reference: Response to Request for Information NP-NLH-004
2 Please provide a graph, similar to Figure 4 - Climatic Ice Loads from MHI DG3 Report
3 in the response to Request for Information NP-NLH-004 that shows the CSA 1:500
4 year reference line based on the 2010 version of the CAN/CSA-C22.3 No. 60826
5 standard.
6
7
- 8 A. As indicated in Hydro's response to NP-NLH-004, a 500-year return period was
9 considered appropriate in Zone 11 given the Labrador-Island Transmission Link's
10 proximity to the existing 230 kV transmission lines on the Avalon Peninsula, and
11 results were compared to a 150-year return period (not a 500-year return period)
12 for zones other than the Avalon Peninsula.
13
- 14 All of the information necessary for Newfoundland Power to produce such a graph
15 if they consider it relevant (including CSA reference loads and relevant conversion
16 factors) is available in Hydro's response to NP-NLH-004.