

1 Q. Reference : Response to the Request for Information NP-NLH-005 (Revision 1,
2 June 3-15), page 1, lines 21-22.

3

4 *“The line is currently planned to be constructed to Hydro’s standard design*
5 *criteria...”*

6

7 Please provide an electronic copy of Hydro’s standard 230kV transmission line
8 design criteria.

9

10

11 A. This statement was intended to refer to the meteorological design criteria as
12 already presented in Hydro's response to NP-NLH-005. As noted in Hydro's
13 response to NP-NLH-083, the meteorological loads are verified to ensure that Hydro
14 meets or exceeds CAN/CSA C22.3 No. 60826-10. All other aspects of the design will
15 be undertaken in accordance with the requirements of the standard.