

1 Q. Reference: *Gas Turbine Failure Analysis, Final Report*, Page 17, Lines 6 to 15.

2

3 Hydro's report references a number of short term reliability measures Hydro
4 intends to implement in relation to the vibration protection and lube oil systems of
5 the Hardwoods and Stephenville units. Is Hydro aiming to implement these
6 measures prior to its planned update to the Board on April 15, 2017? If not, why
7 not?

8

9

10 A. The short term reliability measures listed in Hydro's report, with the possible
11 exception of additional lube oil filtering, will be implemented prior to April 15,
12 2017. The implementation of additional lube oil filtering will require engineering
13 analysis and design to ensure the operational design of the gas turbine lube oil
14 system is not negatively impacted. It is anticipated that this item will be completed
15 by end of Q2, 2017.