1	Q.	Reference PUB-NLH-502: Please provide an update on the progress of the working	
2		group in respect of emergency assistance and reserve sharing, outlining the	
3		definition of the scope, model preparation, study contingencies and project	
4		schedule.	
5			
6			
7	A.	With reference to PUB-NLH-502, the working group sessions were held September	
8		16 – 18, 2015 to develop the scope, model preparation, and schedule. The	
9		transmission service providers within MATPC include Newfoundland and Labrador	
10		Hydro, Nova Scotia Power Inc (NSPI), New Brunswick Power (NBP), Maritime	
11		Electric Company Ltd (MECL), Emera Newfoundland and Labrador (ENL) and	
12		Northern Maine Independent System Administrator (NMISA which includes Emera	
13		Maine Northern Operating Region, EMNOR and Eastern Maine Electric Cooperative,	
14		EMEC). The members of the working group include NLH (through the RFI team),	
15		NSPI, and NBP, with MECL participation as needed to discuss potential impacts on	
16		PEI. EMNOR will not actively participate but stay informed as studies progressed.	
17		EMEC are not involved in the study.	
18			
19		The mandate of working group is to include system study and analysis to	
20		determine:	
21		Atlantic Area Transfer Limits post 2017	
22		Benefits of reserve sharing	
23		Emergency power transfer capability	
24			
25		The working group will review existing studies and relevant documents such as:	
26		Most recent area review reports provided to NPCC	

1	 The individual OATTs of NS and NB for potential language and process
2	New England loss of load limit study
3	NERC standard FAC 13-02 Assessment of Transfer Capability for the Near-
4	Term Transmission Planning Horizon as the basis of study
5	 NERC BAL and EOP standards as they relate to reserve sharing and
6	emergency supply
7	 NPCC Directory 5 – Reserves and Directory 6 – Reserve Sharing Groups
8	 Existing reserve sharing agreement between NBP and NSPI
9	

MATPC Reserve Sharing and Emergency Supply Study				
Date	Scheduled Activity	Status		
Sep 16 – 18, 2015	Kick off Meeting Base case development	 2019 was selected as the base year for the analysis The Eastern Interconnection model was truncated to the NPCC foot print plus NL Four core base cases were developed covering winter peak, summer peak and light load (high wind generation in Maritimes) 		
Sep 18 - Oct 7, 2015	 Complete model building Entities review provincial OATTs and applicable standards 	 From the four core cases a total of nine cases were developed for the dispatches across the NB-NE, NB-NS-PEI, and NS-NL interfaces Each transmission entity has updated the model to include their system upgrades for 2019 		

Page 3 of 5

		 Provincial OATT language permits the concepts of the study
Oct 7, 2015	 Conference call – status update 	Call completed
Oct 7 – 26, 2015	PSS®E analysis	PSS®E analysis ongoing
Oct 26, 2015	Conference call – review preliminary results	 Progress slow due to other priority activities by all utilities
Oct 26 – Dec 7, 2015	 Complete PSS®E analysis 	 Progress slow due to other priority activities by all utilities
Dec 7, 2015	 Conference call – review PSS®E final results 	 Progress slow due to other priority activities by all utilities
Oct 7, 2015 – Jan 11, 2016	Plexos economic analysis of reserve sharing	 Generation planners engaged for Plexos work, delay required until PSS®E analysis results available Estimate spring 2017
Feb 16 – 17, 2016	Face-to-face meeting evaluate and merge results	 Meeting held Mar 21 and 22, 2016 NLH has completed its component of transfer limits indicating A minimum reserve of 154 MW within NL area, up to 229 MW Transfer limit on ML up to 500 MW seasonal dependency, 250 MW firm NBP has completed its component of transfer limits indicating

Review of the NE loss of load limit indicates that ML can be loaded to 375 MW (NS to NL) in all load and NB generation scenarios o Upgrades on 138 kV near the NB-NS-PEI interface result in a firm NB-NS transfer of 200 MW plus TRM of 105 MW There are 130 MW of booking on the interface leaving 70 MW to be offered in an open season in 2016 NSPI are working through its component of transfer limits. o Advise that changes in capital plan will require adjustment to NSPI model and potential impact on NS transfers NSPI advise April 12, 2015 o Preliminary analysis indicates 375 MW can be delivered to the ML Woodbine converter for export to NL through redispatch of Wreck Cove hydro and thermal units at Point Aconi and Lingan, plus operation of NSPI gas turbines and use of up to 170 MW of reserve from NB. The 170 MW would include the

Island Interconnected System Supply Issues and Power Outages

Page 5 of 5

		70 MW of available firm
		capacity on the NB-NS
		interface plus the 105 MW of
		TRM for reserve sharing on
		the interface.
Feb 18 – Mar 30,	 Prepare final report 	Scheduled end of Q3
2016		