

Requests for Information

1 **Q. Further to the response to PUB-NP-001, explain why the Wesleyville gas turbine**
2 **was out of service from January 5-22, 2014.**

3
4 A. Wesleyville gas turbine was out of service on January 5th, 2014 due to a leak in the lube
5 oil cooler.

6
7 Local operators were unable to make the required repairs at the site. Mechanical
8 Maintenance personnel assessed the unit on January 13th, 2014.¹ To repair the unit, the
9 lube oil cooler was dismantled, removed from the site, and taken to a metal fabrication
10 facility for weld repairs. These repairs were completed and the unit went back in service
11 on January 22nd, 2014.

¹ Mechanical maintenance personnel were not available prior to January 13th, 2014 due to commitments to operate the Company's thermal units at Greenhill and Holyrood (Mobile Gas Turbine).