Q. Further to the response to PUB-NP-22, what opportunities are available to minimize the impact on customers of rotating power interruptions which may be necessary in the future and what operational and physical changes, if any, would be required to make these changes?

A. Opportunities to minimize the impact on customers of rotating power outages which may be necessary in the future are available from at least two sources.

8 9

10

11 12

13

The first source is improved availability to Newfoundland Power of real-time data concerning the status of matters on the Island Interconnected System. See the response to Request for Information PUB-NP-047 for further information concerning ongoing efforts by Newfoundland Power to improve real-time data availability to enable it to (i) better anticipate and schedule rotating power outages and (ii) improve its customer communications related to rotating power outages.

14 15 16

17 18

19

20

21 22 The second source is physical changes to Newfoundland Power's electrical distribution system. Increased automation of distribution feeders will permit more efficient rotation of power. Increased capability to sectionalize some of Newfoundland Power's larger distribution feeders will permit a more flexible response to cold load pickup during rotating power outages. See the response to Request for Information PUB-NP-036 for further information concerning increased sectionalization and automation of Newfoundland Power's distribution feeders.

Sectionalizing a distribution feeder involves the operation of a device (typically a type of switch) to reduce the overall customer demand being served by the feeder by disconnecting some, but not all, of the customers served by the feeder.