

Requests for Information

1 **Q. Please describe the extent that distribution feeders have automatic circuit reclosers**
2 **on the feeders downstream from the substations. Provide the percentage of reclosers**
3 **that are SCADA controlled.**

4
5 A. Newfoundland Power has a total of 26 automatic circuit reclosers on 17 feeders located
6 downstream from their respective substations. 12% of these automatic reclosers are
7 SCADA controlled.