

1 **Q. How does Newfoundland Power monitor system demand in real time?**

2
3 A. Newfoundland Power's SCADA system monitors system demand in real time.
4 Telemetry data from Newfoundland and Labrador Hydro's infeed points is received via
5 the ICCP link¹ between Hydro's Energy Management System and the Company's
6 SCADA system. The total system infeed value from Hydro is added to the Company's
7 total generation value to calculate the instantaneous total system demand.

¹ Inter Control Centre Protocol.