

- 1 **Q: (a) Regarding the 110MW of capacity from Labrador recall, is that capacity's**  
2 **availability a constant across all seasons or does it vary over the year?**  
3
- 4 **(b) In particular, has Hydro confirmed that the full 110MW will be available**  
5 **during the winter months?**  
6
- 7
- 8 A. (a) Please refer to Hydro's response to PUB-NLH-630. Table 1 indicates that 114-  
9 117 MW, net of losses, will be available at Soldiers Pond. Hydro indicates that  
10 it based its estimate of 110 MW on this data. Liberty has no direct knowledge  
11 of the degree, if any, that the available recall power will vary during the year.  
12
- 13 (b) Hydro's response to PUB-NLH-630 confirms that the 114-117 MW range  
14 noted in Table 1 is on peak.