

- 1   **Q: What is the estimated energy from the 110 MW of recall power and what are**  
2   **the associated line losses?**  
3  
4
- 5   A. Liberty has no knowledge of how the amount of recall power will vary with time and  
6   therefore has no information on the amount of energy to be delivered over time.  
7
- 8       Based on Hydro's response to PUB-NLH-630, Table 1, line losses at peak are  
9       estimated at 13 MW, or about 10%. Note that the 110 MW delivered to Soldiers  
10      Pond is *after* losses.