Page 1 of 1

2	Q:	Re: Review of Newfoundland and Labrador Hydro Power Supply Adequacy and Reliability Prior to and Post Muskrat Falls ("the Liberty Report #2"), p. 49.
3		and remaining 11101 to and 105t Huski at 1 and ( the Elberty Report #2 ), p. 15.
4		Citation 1:
5		
6		We understand that the HVdc cables may be installed in the summer of 2016,
7		but that the LIL may not be fully operational until 2019. Should this timing
8		occur, the HVdc cable warranty may have expired by the time the scheme is
9		in operation.
10		
11		Please elaborate on the implications of a situation where the HVdc cable
12		warranty has expired before the cable is operational.
13 14		
15	A.	Liberty has not received any information concerning the cable warranty. Typically, a
16		warranty will cover issues such as design and manufacturing defects associated with
17		the cable.
18		
19		The implications of the warranty having expired will depend on whether or not
20		Hydro has negotiated an extension to the warranty, and also how latent defects are
21		covered in the contract.