

- 1 Q. **Reference: Reliability and Resource Adequacy Study 2022 Update, Volume I, Attachment 2.**
- 2 a) Summarize the scope and results of all Daymark, Hydro, or other Nalcor/Hydro experts
- 3 addressing the design bases, conformity of as-built to design, weather-related design
- 4 assumptions versus actual conditions experienced, and other factors bearing on
- 5 performance reliability obtained in northern Europe and how they compare with the same
- 6 factors regarding the LIL.
- 7 b) Describe Hydro’s views on how northern Europe data bears on assessing reliability of the
- 8 LIL, and specifically how consideration of that data has affected planning considerations
- 9 here.
- 10 c) Given experience to date with respect to the LIL, state and describe how Hydro considers it
- 11 is most likely to perform in comparison to the European group analyzed (e.g., first quartile,
- 12 fourth quartile, median, average).
- 13
- 14 A. a) A review of design bases, conformity of as-built to design, and weather-related design
- 15 assumptions versus actual conditions experienced was not performed for HVdc systems in
- 16 northern Europe. Given the significant uncertainty regarding the reliability implications of
- 17 the Labrador-Island Link’s (“LIL”) overhead transmission structures and software at this
- 18 time, direct comparisons are not possible and further review of European HVdc systems
- 19 would not allow for improved precision in Newfoundland and Labrador Hydro’s (“Hydro”)
- 20 perspectives on LIL performance expectations.
- 21 However, the high-level review of European HVdc system performance data has provided
- 22 improved insight to Hydro in other ways. Specifically, Hydro has noted the appreciable
- 23 variations in the reliability of these systems and the various modes of failure that can widely
- 24 impact performance metrics. Based on this data and the uncertainties described herein, it is
- 25 Hydro’s perspective that the unavailability of the LIL would best be represented as a range
- 26 up to 10% at this time.
- 27 b) Hydro does not have a view on how northern Europe data bears on assessing reliability of
- 28 the LIL, other than it provides considerations for HVdc outage and unavailability rates that

1 other utilities or other energy industry participants have experienced. Absent any long-term
2 operational experience with the LIL post-commissioning, the upper and lower bipole limits
3 that Hydro assumed provide a range of values that were used to assess the impact on
4 system reliability, recognizing that the upper bipole limit assumed is reasonable in
5 comparison to other HVdc paths.

6 **c)** Absent any long-term operational experience with the LIL post-commissioning, Hydro does
7 not have the appropriate data available to perform a comparison against other utilities or
8 other energy industry participants.