

1 Q. **Reference: Application, Appendix C 2019 Capital Projects \$500,000 and Over, page**
2 **C-22 “Terminal Station Refurbishment and Modernization”**

3 NLH is engaged in a 30 m\$ Terminal Station Refurbishment and Modernization
4 Program

5

6 Please indicate describe the transmission capacity increase associated with the
7 program, segregating the Lab West and Lab East systems.

8

9

10 A. There is no capacity increase for either the Labrador West or Labrador East systems
11 associated with the “Terminal Station Refurbishment and Modernization” project.

12 The “Terminal Station Refurbishment and Modernization” project consolidates
13 capital activities for sustaining terminal station assets based on Hydro’s asset
14 management strategies outlined in Hydro’s “Terminal Station Asset Management
15 Overview”, found in Volume I, Tab 6 of this Application. Additions for load growth
16 are not addressed within this project.